



**TECHNICAL SUPPORT DOCUMENT**

**Air Discharge Permit ADP 25-3711  
Air Discharge Permit Application L-751**

**Issued: May 28, 2025**

**Centralia School District #401**

**SWCAA ID - 278**

Prepared By: Wess Safford  
Air Quality Engineer  
Southwest Clean Air Agency

**TABLE OF CONTENTS**

| <u>Section</u>                                                                               | <u>Page</u> |
|----------------------------------------------------------------------------------------------|-------------|
| 1. Facility Identification                                                                   | 1           |
| 2. Facility Description                                                                      | 1           |
| 3. Current Permitting Action                                                                 | 1           |
| 4. Process Description                                                                       | 1           |
| 5. Equipment/Activity Identification                                                         | 2           |
| 6. Emissions Determination                                                                   | 5           |
| 7. Regulations and Emission Standards                                                        | 8           |
| 8. RACT/BACT/BART/LAER/PSD/CAM Determinations                                                | 10          |
| 9. Ambient Impact Analysis                                                                   | 10          |
| 10. Discussion of Approval Conditions                                                        | 11          |
| 11. Start-up and Shutdown Provisions/Alternative Operating<br>Scenarios/Pollution Prevention | 12          |
| 12. Emission Monitoring and Testing                                                          | 13          |
| 13. Facility History                                                                         | 13          |
| 14. Public Involvement Opportunity                                                           | 14          |

## ABBREVIATIONS

### *List of Acronyms*

|        |                                                                                                                     |          |                                                                                               |
|--------|---------------------------------------------------------------------------------------------------------------------|----------|-----------------------------------------------------------------------------------------------|
| ADP    | Air Discharge Permit                                                                                                | NSPS     | New Source Performance Standard                                                               |
| AP-42  | Compilation of Emission Factors, AP-42, 5th Edition, Volume 1, Stationary Point and Area Sources – published by EPA | PSD      | Prevention of Significant Deterioration                                                       |
| ASIL   | Acceptable Source Impact Level                                                                                      | RCW      | Revised Code of Washington                                                                    |
| BACT   | Best available control technology                                                                                   | SCC      | Source Classification Code                                                                    |
| CAS#   | Chemical Abstracts Service registry number                                                                          | SDS      | Safety Data Sheet                                                                             |
| CFR    | Code of Federal Regulations                                                                                         | SQER     | Small Quantity Emission Rate listed in WAC 173-460                                            |
| EPA    | U.S. Environmental Protection Agency                                                                                | Standard | Standard conditions at a temperature of 68°F (20°C) and a pressure of 29.92 in Hg (760 mm Hg) |
| EU     | Emission Unit                                                                                                       | SWCAA    | Southwest Clean Air Agency                                                                    |
| NESHAP | National Emission Standards for Hazardous Air Pollutants                                                            | T-BACT   | Best Available Control Technology for toxic air pollutants                                    |
| NOV    | Notice of Violation/                                                                                                | WAC      | Washington Administrative Code                                                                |

### *List of Units and Measures*

|         |                                   |       |                                  |
|---------|-----------------------------------|-------|----------------------------------|
| acfm    | Actual cubic foot per minute      | ppm   | Parts per million                |
| bhp     | Brake horsepower                  | ppmv  | Parts per million by volume      |
| gpm     | Gallon per minute                 | ppmvd | Parts per million by volume, dry |
| gr/dscf | Grain per dry standard cubic foot | ppmw  | Parts per million by weight      |
| hp      | Horsepower                        | rpm   | Revolution per minute            |
| hp-hr   | Horsepower-hour                   | tph   | Ton per hour                     |
| kW      | Kilowatt                          | tpy   | Tons per year                    |
| MMBtu   | Million British thermal unit      |       |                                  |

### *List of Chemical Symbols, Formulas, and Pollutants*

|                  |                                                                                     |                   |                                                     |
|------------------|-------------------------------------------------------------------------------------|-------------------|-----------------------------------------------------|
| CO               | Carbon monoxide                                                                     | PM <sub>10</sub>  | PM with an aerodynamic diameter 10 µm or less       |
| CO <sub>2</sub>  | Carbon dioxide                                                                      | PM <sub>2.5</sub> | PM with an aerodynamic diameter 2.5 µm or less      |
| CO <sub>2e</sub> | Carbon dioxide equivalent                                                           | SO <sub>2</sub>   | Sulfur dioxide                                      |
| HAP              | Hazardous air pollutant listed pursuant to Section 112 of the Federal Clean Air Act | SO <sub>x</sub>   | Sulfur oxides                                       |
| NO <sub>2</sub>  | Nitrogen dioxide                                                                    | TAP               | Toxic air pollutant pursuant to Chapter 173-460 WAC |
| NO <sub>x</sub>  | Nitrogen oxides                                                                     | VOC               | Volatile organic compound                           |
| O <sub>2</sub>   | Oxygen                                                                              |                   |                                                     |
| PM               | Particulate Matter with an aerodynamic diameter 100 µm or less                      |                   |                                                     |

Terms not otherwise defined have the meaning assigned to them in the referenced regulations or the dictionary definition, as appropriate.

## 1. FACILITY IDENTIFICATION

Applicant Name: Centralia School District #401  
 Applicant Address: 123 South Gold Street, Centralia, WA 98531

Facility Name/Address: Centralia High School 813 Eshom Road, Centralia  
 Centralia Middle School 901 Johnson Road, Centralia

SWCAA Identification: 278

Contact Person: Carli Byrer, Facilities and Maintenance Dept

Primary Process: Elementary and Secondary Schools  
 SIC/NAICS Code: 8211 / Elementary and Secondary Schools  
 61111 / Elementary and Secondary Schools

Facility Latitude and Longitude: 46° 43' 33.93" N  
 122° 58' 58.18" W

Facility Classification: Natural Minor

## 2. FACILITY DESCRIPTION

Centralia School District #401 (Centralia) is the primary public education provider for Centralia, Washington. This permitting action is for replacement of equipment as described in Section 3 below.

## 3. CURRENT PERMITTING ACTION

This permitting action is in response to Air Discharge Permit application number L-751 (ADP Application L-751) dated May 1, 2025. Centralia submitted ADP Application L-751 requesting approval of the following:

- Installation of an emergency diesel engine powered generator at Centralia High School; and
- Replacement of (2) existing hot water heaters at Centralia Middle School.

The current permitting action provides approval for installation of new equipment as proposed in ADP Application L-751 and consolidation of existing approvals. ADP 25-3711 will supersede the following orders/approvals in their entirety:

- ADP 10-2943
- SUN 219
- SUN 278
- SUN 218
- SUN 221
- SUN 065
- SUN 220
- SUN 064

## 4. PROCESS DESCRIPTION

- 4.a. Space Heating (existing). Package boilers and heaters are used to provide hot water to hydronic heating systems at associated school campuses. Boilers and heaters typically operate less than half of the year.
- 4.b. Domestic Hot Water (existing). Package hot water heaters are used to provide domestic hot water at associated school campuses.

- 4.c. Emergency Power Generation (existing). A diesel engine driven generator is used to generate emergency electrical power at the high school campus.

## 5. EQUIPMENT/ACTIVITY IDENTIFICATION

- 5.a. Block House (existing). Location: TBD

The following emission units are installed at the Middle School Block House:

| Unit        | Make     | Model | Serial # | Rating         |
|-------------|----------|-------|----------|----------------|
| Hot Water 1 | AO Smith | BC420 | --       | 0.420 MMBtu/hr |
| Hot Water 2 | AO Smith | BC420 | --       | 0.420 MMBtu/hr |

- 5.b. Centralia High School (modified). Location: 46°43'34.85"N 123°0'10.61"W

The following emission units are installed at Centralia High School:

| Unit                                   | Make     | Model                   | Serial #      | Rating          |
|----------------------------------------|----------|-------------------------|---------------|-----------------|
| HWT 1                                  | AO Smith | BTH-199(A)              | 1826110945053 | 0.199 MMBtu/hr  |
| HWT 2                                  | AO Smith | BTH-400(A)              | 1845112518461 | 0.3999 MMBtu/hr |
| HWT 3                                  | AO Smith | BTH-250(A)              | 1904113493013 | 0.250 MMBtu/hr  |
| HWT 4<br>(SUN-278)                     | AO Smith | BTH-500(A)<br>(Low NOx) | 1908113782733 | 0.500 MMBtu/hr  |
| Emergency<br>Generator Engine<br>(new) | Cummins  | QSL9-G2                 | --            | 364 bhp         |

*ADP Application L-751. Centralia is installing a new emergency diesel engine powered generator at the Centralia High School campus. No other changes are proposed at this location.*

- 5.c. Centralia Middle School (modified). Location: 46°43'33.50"N 122°58'57.93"W

The following emission units are installed at Centralia Middle School:

| Unit                      | Make           | Model                 | Serial #       | Rating         |
|---------------------------|----------------|-----------------------|----------------|----------------|
| Boiler 1<br>(ADP 10-2943) | Cleaver Brooks | CFC 1500<br>(Low NOx) | 16010150110003 | 1.5 MMBtu/hr   |
| Boiler 2<br>(ADP 10-2943) | Cleaver Brooks | CFC 1500<br>(Low NOx) | 16010150110001 | 1.5 MMBtu/hr   |
| Hot Water 1               | AO Smith       | BTR 365A 118          | 1138M001963    | 0.365 MMBtu/hr |
| Hot Water 2<br>(new)      | AO Smith       | BTR 500A 130          | 2328134872279  | 0.500 MMBtu/hr |
| Hot Water 3<br>(new)      | AO Smith       | BTR 500A 130          | 2247131838783  | 0.500 MMBtu/hr |

The following insignificant emission units are installed at Centralia Middle School:

- One natural gas fired ceramic kiln.
- A metal foundry area vented to ambient through roof.
- Five instructional welding stations exhausted to ambient air through roof.
- Wood Shop exhausted via Torit cyclone to ambient air.
- Wood finishing room exhausted to ambient air.

*ADP Application L-751. Centralia is replacing two existing water heaters (AO Smith BT-500A 830) with two new water heaters of similar design and capacity (AO Smith BTR-500A 130).*

5.d. Centralia Pool (existing). Location: 46°43'35.43"N 122°58'52.49"W

The following emission units are installed at the Centralia Pool:

| Unit                  | Make           | Model                 | Serial #       | Rating       |
|-----------------------|----------------|-----------------------|----------------|--------------|
| Boiler 1<br>(SUN-065) | Cleaver Brooks | CFC 1500<br>(Low NOx) | 16010150110165 | 1.5 MMBtu/hr |
| Boiler 2<br>(SUN-064) | Cleaver Brooks | CFC 1500<br>(Low NOx) | 16010150110166 | 1.5 MMBtu/hr |

5.e. Edison Elementary School (existing). Location: 46°43'18.59"N 122°57'34.24"W

The following emission units are installed at Edison Elementary School:

| Unit                      | Make           | Model                           | Serial #       | Rating       |
|---------------------------|----------------|---------------------------------|----------------|--------------|
| Boiler 1<br>(ADP 10-2943) | Cleaver Brooks | CFC 700-1000-60 HW<br>(Low NOx) | 16010100010020 | 1.0 MMBtu/hr |
| Boiler 2<br>(ADP 10-2943) | Cleaver Brooks | CFC 700-1000-60 HW<br>(Low NOx) | 16010100010019 | 1.0 MMBtu/hr |

5.f. Fords Prairie Elementary School (existing). Location: 46°44'04.34"N 122°59'12.90"W

The following emission units are installed at Fords Prairie Elementary School:

| Unit                  | Make      | Model                | Serial #       | Rating          |
|-----------------------|-----------|----------------------|----------------|-----------------|
| Boiler 1<br>(SUN-219) | Lochinvar | FBN150<br>(Low NOx)  | 1824 110749504 | 1.5 MMBtu/hr    |
| Boiler 2<br>(SUN-218) | Lochinvar | FBN1501<br>(Low NOx) | 1828 111047565 | 1.5 MMBtu/hr    |
| Hot Water 1           | AO Smith  | Mxi BTH-199          | 1831111438326  | 0.1999 MMBtu/hr |
| Hot Water 2           | AO Smith  | Mxi BTH-199          | 1831111438324  | 0.1999 MMBtu/hr |

5.g. Jefferson-Lincoln Elementary School (existing). Location: 46°42'21.42"N 122°57'45.95"W

The following emission units are installed at Jefferson-Lincoln Elementary School:

| Unit                         | Make      | Model                | Serial #       | Rating         |
|------------------------------|-----------|----------------------|----------------|----------------|
| Boiler 1<br>(SUN-221)        | Lochinvar | FBN1501<br>(Low NOx) | 1828 111047566 | 1.5 MMBtu/hr   |
| Boiler 2<br>(SUN-220)        | Lochinvar | FBN1501<br>(Low NOx) | 1824 110749509 | 1.5 MMBtu/hr   |
| Hot Water 1<br>(ADP 10-2943) | AO Smith  | Mxi BTH-199          | 1831111438352  | 0.199 MMBtu/hr |
| Hot Water 2                  | AO Smith  | Mxi BTH-199          | 1831111438327  | 0.199 MMBtu/hr |

5.h. Logan Elementary School (existing). Location: 46°43'53.93"N 122°56'31.62"W

The following emission units are installed at Logan School:

| Unit                     | Make  | Model       | Serial # | Rating         |
|--------------------------|-------|-------------|----------|----------------|
| Furnace<br>(ADP 10-2943) | Trane | T0140A960K2 | N224SN1G | 0.140 MMBtu/hr |

5.i. Maintenance Department (existing). Location: 46°42'54.71"N 122°57'09.49"W

The following emission units are installed at the Maintenance Department:

| Unit    | Make     | Model     | Serial # | Rating         |
|---------|----------|-----------|----------|----------------|
| Furnace | Reznor   | EEXL225   |          | 0.175 MMBtu/hr |
| Furnace | Reznor   | UDAP22520 |          | 0.250 MMBtu/hr |
| Furnace | Hastings | GB-100Y   |          | 0.100 MMBtu/hr |
| Furnace | Janitrol | 2300      |          | 0.230 MMBtu/hr |
| Furnace | Trane    | XR-90     |          | 0.090 MMBtu/hr |

5.j. Transportation Co-Op (existing). Location: 46°42'48.95"N 122°58'13.35"W

The following emission units are installed at the Transportation Co-Op:

| Unit                           | Make     | Model                          | Serial #  | Rating          |
|--------------------------------|----------|--------------------------------|-----------|-----------------|
| Air Heater<br>(ADP 10-2943)    | Trane    |                                | B81503870 | 5.5 MMBtu/hr    |
| Air Heater<br>(ADP 10-2943)    | Trane    |                                | B81J03869 | 1.1 MMBtu/hr    |
| Hot Water                      | AO Smith |                                |           | 0.0751 MMBtu/hr |
| Gasoline Tank<br>(ADP 10-2943) |          | Underground,<br>submerged fill |           | 12,000 gal      |

The following insignificant emission units are installed at the Transportation Co-Op:

- One abrasive blasting box vented to atmosphere.

5.k. Equipment/Activity Summary.

| ID No. | Equipment/Activity                                                                  | Control Equipment/Measure                                                                           |
|--------|-------------------------------------------------------------------------------------|-----------------------------------------------------------------------------------------------------|
| 1      | Block House<br>(2 Water Heaters)                                                    | Low Sulfur Fuel (Nat gas)                                                                           |
| 2      | Centralia High School<br>(4 Water Heaters, Diesel Engine Generator)                 | Low Sulfur Fuel (Nat Gas),<br>Ultra-low Sulfur Diesel ( $\leq 0.0015\%$ by wt),<br>Emergency Tier 3 |
| 3      | Centralia Middle School<br>(2 Boilers, 3 Water Heaters)                             | Low Sulfur Fuel (Nat Gas)<br>Low Emission Burners (Boilers)                                         |
| 4      | Centralia Pool<br>(2 Boilers)                                                       | Low Sulfur Fuel (Nat Gas)<br>Low Emission Burners                                                   |
| 5      | Edison Elementary School<br>(2 Boilers)                                             | Low Sulfur Fuel (Nat Gas)<br>Low Emission Burners                                                   |
| 5      | Fords Prairie Elementary School<br>(2 Boilers, 2 Water Heaters)                     | Low Sulfur Fuel (Nat Gas)<br>Low Emission Burners (Boilers)                                         |
| 6      | Jefferson-Lincoln Elementary School<br>(2 Boilers, 2 Water Heaters)                 | Low Sulfur Fuel (Nat Gas)<br>Low Emission Burners (Boilers)                                         |
| 7      | Logan Elementary School<br>(1 Furnace)                                              | Low Sulfur Fuel (Nat Gas)                                                                           |
| 8      | Maintenance Department<br>(5 Furnaces)                                              | Low Sulfur Fuel (Nat Gas)                                                                           |
| 9      | Transportation Co-Op<br>(2 Air Heaters, 1 Water Heater, 1 Gasoline<br>Storage Tank) | Low Sulfur Fuel (Nat Gas),<br>Submerged Fill                                                        |

**6. EMISSIONS DETERMINATION**

Emissions to the ambient atmosphere from new and existing equipment proposed in ADP Application L-751 consist of nitrogen oxides (NO<sub>x</sub>), carbon monoxide (CO), volatile organic compounds (VOC), particulate matter (PM), sulfur dioxide (SO<sub>2</sub>), toxic air pollutants (TAPs), and hazardous air pollutants (HAPs).

Unless otherwise specified by SWCAA, actual emissions must be determined using the specified input parameter listed for each emission unit and the following hierarchy of methodologies:

- Continuous emissions monitoring system (CEMS) data;
- Source emissions test data (EPA reference method). When source emissions test data conflicts with CEMS data for the time period of a source test, source test data must be used;
- Source emissions test data (other test method); and
- Emission factors or methodology provided in this TSD.

- 6.a. Low Emission Natural Gas Equipment (*modified*). Potential emissions from low emission natural gas fired equipment are calculated from a combined heat input of 14.0 MMBtu/hr, 4,380 hr/yr (50% capacity), and applicable emission factors. Emission factors for NO<sub>x</sub> and CO correspond to 30 ppmv and 50 ppmv at 3% O<sub>2</sub>, respectively. All other emission factors are taken from EPA AP-42 §1.4 "Natural Gas Combustion" (3/98). All PM is assumed to be PM<sub>2.5</sub>. Annual emissions will be calculated based on actual fuel consumption using the same methodology.

| Heat Input Rating =                | 14.000                        | MMBtu/hr |                      |         |
|------------------------------------|-------------------------------|----------|----------------------|---------|
| Fuel Consumption =                 | 61,320                        | MMBtu/yr |                      |         |
| Pollutant                          | Emission Factor<br>(lb/MMBtu) | (lb/hr)  | Emissions<br>(lb/yr) | (tpy)   |
| NO <sub>x</sub>                    | 0.0364                        | 0.51     | 2,232                | 1.12    |
| CO                                 | 0.0370                        | 0.52     | 2,269                | 1.13    |
| VOC                                | 0.0054                        | 0.08     | 331                  | 0.17    |
| SO <sub>x</sub> as SO <sub>2</sub> | 5.88E-04                      | 8.2E-03  | 36                   | 0.018   |
| PM/PM <sub>10</sub>                | 0.0075                        | 0.10     | 457                  | 0.23    |
| PM <sub>2.5</sub>                  | 0.0075                        | 0.10     | 457                  | 0.23    |
| Benzene                            | 2.06E-06                      | 2.9E-05  | 1.3E-01              | 6.3E-05 |
| Formaldehyde                       | 7.35E-05                      | 1.0E-03  | 4.5E+00              | 2.3E-03 |
| CO <sub>2</sub> e                  | 117                           | 1638.0   | 7,174,440            | 3,587   |

- 6.b. Conventional Natural Gas Equipment (*modified*). Potential emissions from conventional natural gas fired equipment are calculated from a combined heat input of 12.01 MMBtu/hr, 4,380 hr/yr (50% capacity), and emission factors from EPA AP-42 §1.4 "Natural Gas Combustion" (3/98). All PM is assumed to be PM<sub>2.5</sub>. Annual emissions will be calculated based on actual fuel consumption using the same methodology.

| Heat Input Rating =                | 12.010                        | MMBtu/hr |                      |         |
|------------------------------------|-------------------------------|----------|----------------------|---------|
| Fuel Consumption =                 | 52,604                        | MMBtu/yr |                      |         |
| Pollutant                          | Emission Factor<br>(lb/MMBtu) | (lb/hr)  | Emissions<br>(lb/yr) | (tpy)   |
| NO <sub>x</sub>                    | 0.0980                        | 1.18     | 5,155                | 2.58    |
| CO                                 | 0.0820                        | 0.98     | 4,314                | 2.16    |
| VOC                                | 0.0054                        | 0.06     | 284                  | 0.14    |
| SO <sub>x</sub> as SO <sub>2</sub> | 5.88E-04                      | 7.1E-03  | 31                   | 0.015   |
| PM/PM <sub>10</sub>                | 0.0075                        | 0.09     | 392                  | 0.20    |
| PM <sub>2.5</sub>                  | 0.0075                        | 0.09     | 392                  | 0.20    |
| Benzene                            | 2.06E-06                      | 2.5E-05  | 1.1E-01              | 5.4E-05 |
| Formaldehyde                       | 7.35E-05                      | 8.8E-04  | 3.9E+00              | 1.9E-03 |
| CO <sub>2</sub> e                  | 117                           | 1405.2   | 6,154,645            | 3,077   |

- 6.c. Diesel Engine – Centralia High School (new). Potential emissions from emergency engine operation are calculated based on 100 hours per year of operation at full rated load, the use of ultra-low sulfur diesel (<0.0015% sulfur by weight), and a maximum fuel rate of 18.2 gallons per hour. Sulfur oxide emissions are estimated using mass balance methodology, assuming all fuel sulfur is converted to sulfur dioxide. Annual emissions will be calculated from actual hours of operation using the emission factors identified below.

|                         |        |                       |
|-------------------------|--------|-----------------------|
| Hours of Operation =    | 100    | hours                 |
| Power Output =          | 364    | horsepower            |
| Fuel Sulfur Content =   | 0.0015 | % by weight           |
| Fuel Consumption Rate = | 18.20  | gal/hr                |
| Fuel Heat Content =     | 0.138  | MMBtu/gal (40 CFR 98) |

  

| <u>Pollutant</u>                   | <u>EF</u>    | <u>Emissions</u> | <u>EF Source</u>  |
|------------------------------------|--------------|------------------|-------------------|
|                                    | <u>lb/hr</u> | <u>tpy</u>       |                   |
| NO <sub>x</sub>                    | 2.15         | 0.11             | EPA Certification |
| CO                                 | 1.38         | 0.069            | EPA Certification |
| VOC                                | 0.13         | 0.0065           | EPA Certification |
| SO <sub>x</sub> as SO <sub>2</sub> | 0.0039       | 0.00020          | Mass Balance      |
| PM/PM <sub>10</sub>                | 0.06         | 0.0030           | EPA Certification |
| PM <sub>2.5</sub>                  | 0.06         | 0.0030           | EPA Certification |
| DPM                                |              | 0.0030           | DPM = PM          |

  

| <u>Greenhouse Gases</u>       | <u>kg/MMBtu</u> | <u>GWP</u> | <u>CO<sub>2</sub>e</u> |                  | <u>CO<sub>2</sub>e</u>      |           |
|-------------------------------|-----------------|------------|------------------------|------------------|-----------------------------|-----------|
|                               |                 |            | <u>lb/MMBtu</u>        | <u>lb/gallon</u> | <u>tpy, CO<sub>2</sub>e</u> |           |
| CO <sub>2</sub>               | 73.96           | 1          | 163.05                 | 22.501           | 20                          | 40 CFR 98 |
| CH <sub>4</sub>               | 0.003           | 25         | 0.165                  | 0.023            | 0.0                         | 40 CFR 98 |
| N <sub>2</sub> O              | 0.0006          | 298        | 0.394                  | 0.054            | 0.0                         | 40 CFR 98 |
| Total GHG - CO <sub>2</sub> e | 73.9636         |            | 163.61                 | 22.58            | 20.5                        |           |

- 6.d. Emissions Summary/Facility-wide Potential to Emit. Facility-wide potential to emit as calculated in the sections above is summarized below.

| <u>Pollutant</u>  | <u>Potential Emissions (tpy)</u> | <u>Project Increase (tpy)</u> |
|-------------------|----------------------------------|-------------------------------|
| NO <sub>x</sub>   | 3.69                             | 0.11                          |
| CO                | 3.29                             | 0.069                         |
| VOC               | 0.31                             | 0.0065                        |
| SO <sub>2</sub>   | 0.034                            | 0.00020                       |
| Lead              | 0.00                             | 0.00                          |
| PM                | 0.43                             | 0.0030                        |
| PM <sub>10</sub>  | 0.43                             | 0.0030                        |
| PM <sub>2.5</sub> | 0.43                             | 0.0030                        |
| TAP               | 0.0043                           | 0.0030                        |
| HAP               | 0.0043                           | 0.0030                        |
| CO <sub>2</sub> e | 6,684.5                          | 20.5                          |

| Pollutant                  | CAS Number | Category | Facility-wide Emissions (lb/yr) | Project Increase (lb/yr) | WAC 173-460 SQER (lb/yr) |
|----------------------------|------------|----------|---------------------------------|--------------------------|--------------------------|
| Benzene                    | 71-43-2    | HAP/TAP  | 0.23                            | 0.0                      | 20                       |
| Diesel Exhaust Particulate | --         | TAP      | 6.0                             | 6.0                      | 0.54                     |
| Formaldehyde               | 50-00-0    | HAP/TAP  | 8.4                             | 0.0                      | 20                       |

## 7. REGULATIONS AND EMISSION STANDARDS

Regulations that have been used to evaluate the acceptability of the proposed facility and establish emission limits and control requirements include, but are not limited to, the regulations, codes, or requirements listed below.

- 7.a. Title 40 Code of Federal Regulations Part 60 (40 CFR 60) Subpart IIII "Standards of Performance for Stationary Compression Ignition Internal Combustion Engines" applies to each compression ignition (CI) internal combustion engine (ICE) that commences construction after July 11, 2005 and is manufactured after April 1, 2006, or that is modified or reconstructed after July 11, 2005. This regulation is applicable to the emergency generator's power unit.
- 7.b. 40 CFR 63 Subpart ZZZZ "National Emissions Standards for Hazardous Air Pollutants (NESHAP) for Stationary Reciprocating Internal Combustion Engines" establishes national emission limitations and operating limitations for HAP emitted from stationary reciprocating internal combustion engines (RICE) located at major and area sources of HAP emissions. This regulation is applicable to the emergency generator's power unit. Pursuant to 40 CFR 63.6590(c), the unit complies with this regulation by complying with 40 CFR 60 Subpart IIII.
- 7.c. 40 CFR 63 Subpart DDDDD "National Emission Standards for Hazardous Air Pollutants for Major Sources: Industrial, Commercial, and Institutional Boilers and Process Heaters" applies to new, reconstructed, and existing any Industrial, Commercial, and Institutional Boiler and Process Heater located at a major source of hazardous air pollutants. This facility is not a major source so this regulation is not applicable.
- 7.d. 40 CFR 63 Subpart JJJJJ "National Emission Standards for Hazardous Air Pollutants for Industrial, Commercial, and Institutional Boilers Area Sources" establishes performance standards and requirements for industrial, commercial and institutional boilers operating at an area source of hazardous air pollutants. The boilers at this facility are "gas-fired boilers" and not subject to Subpart JJJJJ.
- 7.e. Revised Code of Washington (RCW) 70A.15.2040 empowers any activated air pollution control authority to prepare and develop a comprehensive plan or plans for the prevention, abatement and control of air pollution within its jurisdiction. An air pollution control authority may issue such orders as may be necessary to effectuate the purposes of the Washington Clean Air Act and enforce the same by all appropriate administrative and judicial proceedings subject to the rights of appeal as provided in Chapter 62, Laws of 1970 ex. sess.
- 7.f. RCW 70A.15.2210 provides for the inclusion of conditions of operation as are reasonably necessary to assure the maintenance of compliance with the applicable ordinances, resolutions, rules and regulations when issuing an Air Discharge Permit for installation and establishment of an air contaminant source.

- 7.g. Washington Administrative Code (WAC) 173-460 "Controls for New Sources of Toxic Air Pollutants" requires Best Available Control Technology for toxic air pollutants (T-BACT), identification and quantification of emissions of toxic air pollutants and demonstration of protection of human health and safety.
- 7.h. WAC 173-476 "Ambient Air Quality Standards" establishes ambient air quality standards for PM<sub>10</sub>, PM<sub>2.5</sub>, lead, sulfur dioxide, nitrogen dioxide, ozone, and carbon monoxide in the ambient air, which shall not be exceeded.
- 7.i. SWCAA 400-040 "General Standards for Maximum Emissions" requires all new and existing sources and emission units to meet certain performance standards with respect to Reasonably Available Control Technology (RACT), visible emissions, fallout, fugitive emissions, odors, emissions detrimental to persons or property, sulfur dioxide, concealment and masking, and fugitive dust.
- 7.j. SWCAA 400-050 "Emission Standards for Combustion and Incineration Units" requires that all provisions of SWCAA 400-040 be met and that no person shall cause or permit the emission of particulate matter from any combustion or incineration unit in excess of 0.23 grams per dry cubic meter (0.1 grains per dry standard cubic foot) of exhaust gas at standard conditions.
- 7.k. SWCAA 400-060 "Emission Standards for General Process Units" prohibits particulate matter emissions from all new and existing process units in excess of 0.1 grains per dry standard cubic foot of exhaust gas.
- 7.l. SWCAA 400-109 "Air Discharge Permit Applications" requires that an Air Discharge Permit application be submitted for all new installations, modifications, changes, or alterations to process and emission control equipment consistent with the definition of "new source". Sources wishing to modify existing permit terms may submit an Air Discharge Permit application to request such changes. An Air Discharge Permit must be issued, or written confirmation of exempt status must be received, before beginning any actual construction, or implementing any other modification, change, or alteration of existing equipment, processes, or permits.
- 7.m. SWCAA 400-110 "New Source Review" requires that SWCAA issue an Air Discharge Permit in response to an Air Discharge Permit application prior to establishment of the new source, emission unit, or modification.
- 7.n. SWCAA 400-113 "Requirements for New Sources in Attainment or Nonclassifiable Areas" requires that no approval to construct or alter an air contaminant source shall be granted unless it is evidenced that:
- (1) The equipment or technology is designed and will be installed to operate without causing a violation of the applicable emission standards;
  - (2) Best Available Control Technology will be employed for all air contaminants to be emitted by the proposed equipment;
  - (3) The proposed equipment will not cause any ambient air quality standard to be exceeded; and
  - (4) If the proposed equipment or facility will emit any toxic air pollutant regulated under WAC 173-460, the proposed equipment and control measures will meet all the requirements of that Chapter.

## 8. RACT/BACT/BART/LAER/PSD/CAM DETERMINATIONS

The proposed equipment and control systems incorporate Best Available Control Technology (BACT) for the types and amounts of air contaminants emitted by the processes as described below:

### New BACT Determinations

- 8.a. BACT Determination – Water Heaters. The proposed use of low sulfur fuel (natural gas) and proper combustion controls has been determined to meet the requirements of BACT for the new water heaters at Centralia Middle School.
- 8.b. BACT Determination – Emergency Generator. The proposed use of a modern diesel engine design (EPA Tier 3), limited hours of operation (testing, maintenance, and emergency use only), and ultra-low sulfur distillate fuel (less than 0.0015% sulfur by weight) has been determined to meet the requirements of BACT for the new emergency generator at Centralia High School.

### Previous BACT Determinations

- 8.c. BACT Determination – Hot Water Boilers (*ADP 10-2943*). The proposed use of low sulfur fuel (natural gas), low emission burner technology, annual emission monitoring, and proper combustion controls has been determined to meet the requirements of BACT for the boilers proposed for installation at Centralia Middle School, Edison Elementary School, and Jefferson-Lincoln Elementary School.

### Other Determinations

- 8.d. Prevention of Significant Deterioration (PSD) Applicability Determination. The potential to emit of this facility is less than applicable PSD applicability thresholds. Likewise, this permitting action will not result in a potential increase in emissions equal to or greater than the PSD thresholds. Therefore, PSD review is not applicable to this action.
- 8.e. Compliance Assurance Monitoring (CAM) Applicability Determination. CAM is not applicable to any emission unit at this facility because it is not a major source and is not required to obtain a Part 70 permit.

## 9. AMBIENT IMPACT ANALYSIS

- 9.a. Criteria Air Pollutant Review. Criteria pollutant emissions from approved operations are not expected to cause an adverse impact on ambient air quality.
- 9.b. TAP Small Quantity Review. The incremental increases in TAP emissions associated with this permitting action are quantified in Section 6 of this Technical Support Document. The incremental increase in potential emissions of diesel exhaust particulate exceed the applicable small quantity emission rate (SQER) identified in WAC 173-460.
- 9.c. TAP Ambient Impact Analysis – Diesel Exhaust Particulate. Emissions of diesel exhaust particulate were modeled using the AERSCREEN dispersion model (ver 16216). The results of the model indicate that the project will not cause an incremental increase in ambient concentrations greater than the applicable acceptable source impact level (ASIL) identified in WAC 173-460.

| <b>Toxic Compound</b>      | <b>CAS #</b> | <b>Incremental Ambient Impact (<math>\mu\text{g}/\text{m}^3</math>)</b> | <b>Acceptable Source Impact Level (<math>\mu\text{g}/\text{m}^3</math>)</b> |
|----------------------------|--------------|-------------------------------------------------------------------------|-----------------------------------------------------------------------------|
| Diesel Exhaust Particulate | --           | 0.0012 (Annual)                                                         | 0.0033 (Annual)                                                             |

### Conclusions

- 9.d. Installation of new equipment, as proposed in ADP Application L-751, will not cause the ambient air quality requirements of Title 40 Code of Federal Regulations (CFR) Part 50 "National Primary and Secondary Ambient Air Quality Standards" to be violated.
- 9.e. Installation of new equipment, as proposed in ADP Application L-751, will not cause the requirements of WAC 173-460 "Controls for New Sources of Toxic Air Pollutants" or WAC 173-476 "Ambient Air Quality Standards" to be violated.
- 9.f. Installation of new equipment, as proposed in ADP Application L-751, will not cause a violation of emission standards for sources as established under SWCAA General Regulations Sections 400-040 "General Standards for Maximum Emissions," 400-050 "Emission Standards for Combustion and Incineration Units," and 400-060 "Emission Standards for General Process Units."

## 10. DISCUSSION OF APPROVAL CONDITIONS

SWCAA has made a determination to issue ADP 25-3711 in response to ADP Application L-751. ADP 25-3711 contains approval requirements deemed necessary to assure compliance with applicable regulations and emission standards as discussed below.

- 10.a. Supersession of Previous Permits. ADP 25-3711 supersedes the following orders/approvals in their entirety:
- ADP 10-2943
  - SUN 219
  - SUN 278
  - SUN 218
  - SUN 221
  - SUN 065
  - SUN 220
  - SUN 064
- 10.b. General Basis. Permit requirements for equipment affected by this permitting action incorporate the operating schemes proposed by the applicant in ADP Application L-751. Permit requirements established by this action are intended to implement BACT, minimize emissions, and assure compliance with applicable requirements on a continuous basis. Emission limits for approved equipment are based on the maximum potential emissions calculated in Section 6 of this Technical Support Document.
- 10.c. Monitoring and Recordkeeping Requirements. ADP 25-3711 establishes monitoring and recordkeeping requirements sufficient to document compliance with applicable emission limits, ensure proper operation of approved equipment and provide for compliance with generally applicable requirements. Specific monitoring requirements are established for fuel consumption and hours of operation.
- 10.d. Reporting Requirements. ADP 25-3711 establishes general reporting requirements for annual air emissions, upset conditions, and excess emissions. Specific reporting requirements are established for fuel consumption and hours of operation. Reports are to be submitted on an annual basis.

- 10.e. Boilers and Water Heaters. Annual emission limits for approved boilers and water heaters are established at the quantity of emissions anticipated from the operation of each unit for 4,380 hours per year (50% capacity) at full rated load using the emission factors supplied in Section 6. This capacity level is a conservative estimate of maximum actual operation. Units with low emission burners are required to take corrective action whenever performance monitoring indicates that short-term emission concentrations exceed 30 ppmvd NO<sub>x</sub> @ 3% O<sub>2</sub> or 50 ppmvd CO @ 3% O<sub>2</sub>. Performance monitoring was paired with appropriate corrective action to maintain these levels. Visible emissions from the natural gas-fired emission units were limited to 0% opacity.
- 10.f. Emergency Generator. Permit requirements for the diesel engine powered emergency generator are based on limited service ( $\leq 100$  hr/yr testing and maintenance) and the use of ultra-low sulfur diesel ( $\leq 0.0015\%$  S by weight). A visible emission limit of 5% opacity has been established consistent with proper operation of the diesel engine. Due to the technical limitations of the engine, the opacity limit does not apply during periods of start-up and shutdown. Annual operation will be monitored with an integral hourmeter and reported to SWCAA by the permittee.
- 10.g. Requirements for Unmodified Emission Units. Permit requirements for existing emission units not affected by ADP Application L-751 are carried forward unchanged from previous approvals.

## **11. START-UP AND SHUTDOWN/ALTERNATIVE OPERATING SCENARIOS/POLLUTION PREVENTION**

- 11.a. Start-up and Shutdown Provisions. Pursuant to SWCAA 400-081 "Start-up and Shutdown", technology based emission standards and control technology determinations shall take into consideration the physical and operational ability of a source to comply with the applicable standards during start-up or shutdown. Where it is determined that a source is not capable of achieving continuous compliance with an emission standard during start-up or shutdown, SWCAA shall include appropriate emission limitations, operating parameters, or other criteria to regulate performance of the source during start-up or shutdown.
- Emergency Engine. Visible emissions from the emergency generator diesel engine are limited to 5% opacity or less during normal operation. However, the engine is not capable of reliably limiting visible emissions to less than 5% opacity until the engine achieves normal operating temperature. Therefore, the 5% opacity limit does not apply to the generator exhaust during start-up periods.
- 11.b. Alternate Operating Scenarios. SWCAA conducted a review of alternate operating scenarios applicable to equipment affected by this permitting action. The permittee did not propose or identify any applicable alternate operating scenarios. Therefore, none were included in the permit requirements.
- 11.c. Pollution Prevention Measures. SWCAA conducted a review of possible pollution prevention measures for the facility. No pollution prevention measures were identified by either the permittee or SWCAA separate from those measures required under BACT considerations. Therefore, none were included in the permit requirements.

## 12. EMISSION MONITORING AND TESTING

- 12.a. Emission Monitoring. Emission monitoring of the equipment listed below is required on a continuing 12-month cycle for the purpose of assuring proper ongoing operation. All emission monitoring must be conducted in accordance with ADP 25-3711, Appendix A.

| <u>Facility</u>                     | <u>Emission Unit(s)</u> |
|-------------------------------------|-------------------------|
| Centralia High School               | Hot Water 4             |
| Centralia Middle School             | Boiler 1, Boiler 2      |
| Centralia Pool                      | Boiler 1, Boiler 2      |
| Edison Elementary School            | Boiler 1, Boiler 2      |
| Fords Prairie Elementary School     | Boiler 1, Boiler 2      |
| Jefferson-Lincoln Elementary School | Boiler 1, Boiler 2      |

## 13. FACILITY HISTORY

- 13.a. Previous Permitting Actions. SWCAA has previously issued the following Permits/Approvals for this facility:

| <u>Permit Number</u> | <u>Application Number</u> | <u>Date</u> | <u>Purpose</u>                                                                                                                                                                                                                                   |
|----------------------|---------------------------|-------------|--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| SUN-278              | --                        | 4/6/2022    | Installation of AO Smith BTH-500A hot water boiler at Centralia High School.                                                                                                                                                                     |
| SUN-221              | --                        | 12/18/2019  | Installation of Lochinvar FBN 1501 hot water boiler at Jefferson-Lincoln Elementary School.                                                                                                                                                      |
| SUN-220              | --                        | 12/18/2019  | Installation of Lochinvar FBN 1501 hot water boiler at Jefferson-Lincoln Elementary School.                                                                                                                                                      |
| SUN-219              | --                        | 12/18/2019  | Installation of Lochinvar FBN 1501 hot water boiler at Fords Prairie Elementary School.                                                                                                                                                          |
| SUN-218              | --                        | 12/18/2019  | Installation of Lochinvar FBN 1501 hot water boiler at Fords Prairie Elementary School.                                                                                                                                                          |
| SUN-065              | --                        | 8/13/2014   | Installation of Cleaver Brooks CFC 1500 hot water boiler at Centralia Pool.                                                                                                                                                                      |
| SUN-064              | --                        | 8/13/2014   | Installation of Cleaver Brooks CFC 1500 hot water boiler at Centralia Pool.                                                                                                                                                                      |
| 10-2943              | L-644                     | 7/27/2010   | Installation of replacement hot water boilers at Centralia Middle School, Edison Elementary School, and Jefferson-Lincoln Elementary School.                                                                                                     |
| 02-2435              | L-503                     | 11/13/2002  | Installation of two replacement hot water boilers at Centralia Middle School. Superseded by ADP 10-2943.                                                                                                                                         |
| 85-774               | L-134                     | 3/7/1985    | Installation of (1) 12,000 gallon and (1) 6,000 gallon underground gasoline storage tanks and Universal Equipment "glove box" type bead blaster at bus facility at Chestnut and Marsh streets (Transportation Co-Op). Superseded by ADP 10-2943. |

- 13.b. Compliance History. A search of source records on file at SWCAA identified the following compliance issues during the past 5 years:

| <u>Date</u> | <u>NOV<br/>Number</u> | <u>Violation</u>                                                                                           |
|-------------|-----------------------|------------------------------------------------------------------------------------------------------------|
| 2/26/2025   | 11396                 | Installation of two natural gas fired hot water heaters and an emergency generator without prior approval. |
| 6/8/2023    | 10844                 | Failure to submit 2022 emissions inventory in violation of Air Discharge Permit10-2943.                    |
| 4/7/2022    | 10581                 | Installation of a natural gas fired hot water heater without prior approval.                               |

#### 14. PUBLIC INVOLVEMENT OPPORTUNITY

- 14.a. Public Notice for ADP Application L-751. Public notice for ADP Application L-751 was published on the SWCAA internet website for a minimum of 15 days beginning on May 8, 2025.
- 14.b. Public/Applicant Comment for ADP Application L-751. SWCAA did not receive specific comments, a comment period request or any other inquiry from the public regarding this ADP application. Therefore, no public comment period was provided for this permitting action.
- 14.c. State Environmental Policy Act. This project is exempt from SEPA requirements pursuant to WAC 197-11-800(3) since it only involves repair and/or maintenance of existing structures, equipment or facilities, and will not involve material expansions or changes in use. SWCAA has made a Determination of SEPA Exempt (SWCAA 25-026) concurrent with issuance of ADP 25-3711.